



Ref. Certif. No.

**ES2671-AENOR**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

## CB TEST CERTIFICATE

Product

INDUSTRIAL CABLES OF RATED VOLTAGE 0,6 /1 KV. PVC  
INSULATED AND PVC SHEATHED CABLES.

Name and address of the applicant

ERBIL COPPER & CABLE COMPANY  
MAKHMOR ROAD TIMMAR  
44001 (IRAQ)

Name and address of the manufacturer

SAME AS ABOVE

Name and address of the factory

SAME AS ABOVE

*Note: When more than one factory, please report on page 2*

☐ Additional Information on page 2

Ratings and principal characteristics

1x95mm<sup>2</sup>; 0,6/1kV

Trademark (if any)

ECC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NY Y (CU/PVC/PVC) - 0,6/1 kV – 1x95mm<sup>2</sup>

Additional information (if necessary may also be  
reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with

IEC 60502-1:2021

As shown in the Test Report Ref. No. which forms part  
of this Certificate

CEL-1137/23-1

This CB Test Certificate is issued by the National Certification Body

AENOR CONFÍA S.A.U.  
CI Génova, 6  
ES-28004 MADRID (SPAIN)

Date: 2024-02-21

Signature: Rafael GARCÍA MEIRO  
CEO